



OFFICE OF PROCUREMENT SERVICES
315 WEST MAIN STREET, SUITE 441
PO BOX 7800
TAVARES FL 32778-7800

PHONE: (352) 343-9839
FAX: 352) 343-9473

ADDENDUM NO. 2
November 4, 2015

ITB 16-0604
HVAC Filters

It is the vendor's responsibility to ensure their receipt of all addenda, and to clearly acknowledge all addenda within their initial bid or proposal response. Acknowledgement may be confirmed either by inclusion of a signed copy of this addendum within the bid response, or by completion and return of the addendum acknowledgement section of the solicitation. Failure to acknowledge each addendum may prevent the bid or proposal from being considered for award.

This addendum does not change the date for receipt of bids or proposals.

Questions regarding this solicitation were due October 30, 2015. The purpose of this addendum is to address additional questions received by the deadline.

Question 3: I would like to confirm that these filters we are quoting for Lake County Florida are pleated. Is it possible for you to confirm this information for us?

Answer 3: The filters are merv 8, pleated.

Acknowledgement of receipt of Addendum:

Firm Name: _____ Date: _____

Signature: _____ Title: _____

Typed/Printed Name: _____